

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 27

Dated: 07.09.2026

It is certified that an inspection team headed by Neha Verma (A.E.)
(Name of Officers with designation) from Public Health Engineering Department (PHED)
inspected the Ishwari Devi International Public School, Village- Lahdara, Bhopal Road
Sagar MP on 07.09.2026 and on the basis of Water Test Report (Attached) bearing no.
27 dated 08/09/2026 of PHED Lab certified that the
Ishwari Devi International Public School has safe drinking water facilities for the
students and members of staff of the institution. School also maintains the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the
Central/State/U.T. Govt.

This certificate is valid till one year

Signature with Seal: [Signature]
सहायक इंजीनियर

Name: Neha Verma

Designation: Asst. Engineer

Name & Address of the Office / Department: PHED

To

Ishwari Devi International Public School

Village- Lahdara, Bhopal Road, Sagar MP

Note: The certificate is to be issued by authorized officer / PHED Lab / local
bodies

[Signature]
PRESIDENT
Smt. Ishwari Devi Welfare Society
Village Lahdara, Sagar (M.P.)

[Signature]
PRINCIPAL
Ishwari Devi International
Public School
Village Lahdara, Sagar (M.P.)

District Water testing Laboratory, (D.W.T.L.)
Public Health Engineering Department, P.H.E.D.
Near Tahseel Sagar
Test Report

Issue No 27

D.W.T.L./PHED/SAG /2026-27

Issue Date 08/09/2026

Source of sample : Drinking Water Sample / Others	Not sampled by District Water testing Lab		Unique Identification No.
Sender's name and address: ISHWARI DEVI INTERNATIONAL PUBLIC SCHOOL VILLAGE LAHDARA, BHOPAL ROAD, SAGAR	Sender's letter no. DWIT Ref. No	27/26	Sender's letter Date DWIT receipt date
	Date of analysis started	07/09/2026	Date of analysis completed
	Quantity Of sample	2 LITR	08/09/2026

Sample details

Particulars of Samples :-

No	Block	Panchayat	Village	Location
	SAGAR	LAHDARA	LAHDARA	IN SCHOOL (DRINKING WATER)

No	Characteristics, unit and test methods	RESULTS BIS-10500:2012		Test Results			
		Desirable Limit	Permissible Limit	1	2	3	4
1	2	3	4				
1*	Chloride as Cl in mg/l, (IS 3025 Part 32)	250	1000	95			
2*	Total Alkalinity as CaCO ₃ in mg/l, (IS 3025 Part 23)	200	600	140			
3*	Calcium as Ca ⁺⁺ in mg/l, (IS 3025 Part 40)	75	200	110			
4*	Magnesium as Mg ⁺⁺ in mg/l, (IS 3025 Part 46)	30	100	48.2			
5*	Total hardness as CaCO ₃ in mg/l, (IS 3025 Part 21)	200	600	460			
6	pH (pH scale)	6.5 to 8.5	6.5 to 8.5	7.3			
7	Iron as Fe Mg/l	1.0	1.0	0.24			
8	Nitrate as NO ₃ Mg/l	45	45	16.6			
9	Fluoride as F Mg/l	1.0	1.5	0.18			
10	TDS Mg/l	500	2000	417.9			
11	Turbidity NTU	1.0	5.0	0.8			
12	Sulphate as SO ₄ Mg/l	200	400	28.12			
13	Manganese as Mn Mg/l	0.1	0.3	0.08			
14	Faecal Coliform (FIC) per 100 ml	NIL					
15	Total Coliform per 100 ml	NIL for treated water and water in distribution system		NIL			
16	Arsenic By Kit Mg/l	0.01	0.01				

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 7 days from the date of issue of report. (For tests from S.No. 1 to 17)
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
6. The tests marked with an * are accredited by NABL.

Remark:-

Reviewed

Authorised Signatory

श्रीमती. शिवम देवी
श्रीमती. शिवम देवी
श्रीमती. शिवम देवी

PRESIDENT
Smt. Ishwari Devi Welfare Society
Village Lahdara, Sagar (M.P.)

PRINCIPAL
Ishwari Devi International
Public School
Village Lahdara, Sagar (M.P.)